

STANDARD

ANSI/ASHRAE/ASHE Standard 189.3-2017

Design, Construction, and Operation of Sustainable High-Performance Health Care Facilities

Approved by the ASHRAE Standards Committee on March 1, 2017; by the ASHRAE Board of Directors on March 10, 2017; by the American Society for Healthcare Engineering on February 22, 2017; and by the American National Standards Institute on April 1, 2017.

This Standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the Standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE website (www.ashrae.org) or in paper form from the Senior Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2017 ASHRAE

ISSN 1041-2336



ASHRAE Standard Project Committee 189.3
Cognizant TC: 9.6, Healthcare Facilities
Supporting TC: 2.8, Building Environmental Impacts and Sustainability
SPLS Liaison: Walter T. Grondzik
ASHRAE Staff Liaison: Mark Weber
ASHE Liaisons: Chad E. Beebe and Dale Woodin
Consultant: Richard D. Hermans

Michael P. Sheerin, <i>Chair*</i>	David Hale*	Steven O. Guttman
Walter N. Vernon, <i>Vice-Chair*</i>	Josh Jacobs*	Carl N. Lawson
Francis J. Babineau, Jr.*	Michael R. Keen*	Stephany I. Mason
Charles H. Beach*	Michael D. Lane*	Richard D. Moeller*
Edward S. Chessor*	Timothy M. Earhart	R. Gregg Moon
David R. Conover	Douglas D. Fick	Jane Rohde*
Douglass S. Erickson	Nicholas R. Ganick	Chris P. Rousseau
Kimball E. Ferguson*	Paula P. Gillette	Anand K. Seth
Jonathan J. Flannery*	Melvin G. Glass	Robert J. VanRees

* Denotes members of voting status when the document was approved for publication

The committee also recognizes and remembers the contributions of Judene Bartley. Her knowledge of her craft and her willingness to listen to and share and work with the ASHRAE committees with a focus on healthcare made us a better organization. We thank her and miss her.

ASHRAE STANDARDS COMMITTEE 2016–2017

Rita M. Harrold, <i>Chair</i>	Michael W. Gallagher	Cyrus H. Nasseri
Steven J. Emmerich, <i>Vice-Chair</i>	Walter T. Grondzik	David Robin
James D. Aswegan	Vinod P. Gupta	Peter Simmonds
Niels Bidstrup	Susanna S. Hanson	Dennis A. Stanke
Donald M. Brundage	Roger L. Hedrick	Wayne H. Stoppelman, Jr.
Drury B. Crawley	Rick M. Heiden	Jack H. Zarour
John F. Dunlap,	Srinivas Katipamula	William F. Walter, <i>BOD ExO</i>
James W. Earley, Jr.	Cesar L. Lim	Patricia Graef, <i>CO</i>
Keith I. Emerson	Arsen K. Melikov	
Julie M. Ferguson	R. Lee Millies, Jr.	

Stephanie C. Reiniche, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS
ANSI/ASHRAE/ASHE Standard 189.3-2017
Design, Construction, and Operation of
Sustainable High-Performance Health Care Facilities

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope	2
3 Definitions, Abbreviations, and Acronyms	2
4 Administration and Enforcement	3
5 Site Sustainability	4
6 Water Use Efficiency	4
7 Energy Efficiency	5
8 Indoor Environmental Quality (IEQ)	6
9 The Building's Impact on Materials and Resources	8
10 Construction and Plans for Operation	8
11 Emissions, Effluent, and Pollution Control	9
12 Normative References	12
Informative Appendix I: Informative References	18
Informative Appendix J: Materials and Resources	19
Informative Appendix K: Emissions, Effluents, and Pollution Control	20

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2017 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

ASHRAE/ASHE Standard 170 addresses the specific ventilation requirements of a health care facility separately from the general ventilation requirements of ASHRAE Standard 62.1.

Similarly, ASHRAE/ASHE Standard 189.3 was developed parallel to yet separately from ASHRAE/USGBC/IES Standard 189.1 to address the sustainability of health care facilities. Standard 189.1 provided a solid foundation and a clear path for the development of Standard 189.3 and, as such, is employed here as an essential, primary reference.

The development of Standard 189.3 presented unique challenges to the accurate reference of its primary sources. Standard 90.1 forms the basis for Standard 189.1, which in turn serves as the basis for Standard 189.3. Because these standards are revised on separate continuous maintenance schedules, the committee debated over which criteria were necessary to include in this document. We acknowledge that the source publications that form the basis for compliance have, in some cases, moved forward without us. In order to join the process of continuous improvement, we have to establish a point at which to begin. The objective of the committee is to align development of this standard with the development of Standards 90.1 and 189.1, and thus to benefit from those efforts, while providing the alternative perspective of this subset of the building sector.

Health care facilities have a substantial interest in sustainable development. These facilities are often the largest and most energy intensive buildings in a community, and their leadership recognizes that opportunities to conserve energy and reduce operating costs are matters of sound environmental and fiscal stewardship. In a competitive and regulated market, however, there are limitations on the ability of health care facilities to provide the necessary capital for the increasingly complex new facilities needed to meet sustainability objectives, particularly as these facilities experience eroding financial compensation for their life-sustaining services. Likewise, sustainability requirements often diverge from facility functions that may require energy consumption for the sake of patient and worker safety. The intent of this standard is to bridge the goal of sustainability offered in Standard 189.1 with the practical realities expressed by our partners in the health care community.

1. PURPOSE

The purpose of this standard is to prescribe the procedures, methods, and documentation requirements for the design, construction, and operation of high-performance, sustainable health care facilities.

2. SCOPE

2.1 This standard applies to patient care areas and related support areas within health care facilities, including hospitals, nursing facilities, outpatient facilities, and their site.

2.2 This standard applies to new buildings, additions to existing buildings, and those alterations to existing buildings that are identified within the standard.

2.3 This standard provides procedures for the integration of sustainable principles into the health care facility design, construction, and operation process, including

- a. integrated design,
- b. conservation of water,
- c. conservation of energy,
- d. indoor environmental quality (IEQ),
- e. construction practices,
- f. commissioning, and
- g. operations and maintenance.

3. DEFINITIONS, ABBREVIATIONS, AND ACRONYMS

3.1 General. Certain terms, abbreviations, and acronyms are defined in this section for the purposes of this standard. These definitions are applicable to all sections of the standard.

Terms that are not defined herein but that are defined in standards that are referenced herein shall have the meanings as defined in those standards.

Other terms that are not defined shall have their ordinarily accepted meanings within the context in which they are used. Ordinarily accepted meanings shall be based on American Standard English language usage as documented in an unabridged dictionary accepted by the authority having jurisdiction (AHJ).

3.2 Definitions

hand-washing station: an area that provides a sink with hot- and cold-water supply and a faucet that facilitates easy on/off/mixing capabilities. The station also provides cleansing agents and means for drying hands.

patient: a person receiving medical, surgical, or psychiatric care in an inpatient or outpatient facility.

public areas: designated spaces freely accessible to the public. These include parking areas, secured entrances and areas, entrance lobbies, reception and waiting areas, public toilets, snack bars, cafeterias, vending areas, gift shops and other retail locations, health education libraries and meeting rooms, chapels, and gardens.

resident: a person living and receiving chronic or subacute care in an assisted living facility, skilled nursing facility, nursing home, hospice, or rehabilitation facility.

residential health care facility: a facility, building, or portion of a building that provides housing and services for a resident or group of residents.

room: a space enclosed by hard walls and having a door.