

△△ Contents

The Interprovincial Gas Advisory Council *vii*

The CSA B149 Installation Code Committee *ix*

Preface *xi*

1 Scope 1

2 Reference publications 2

3 Definitions 5

4 General 18

- 4.1 Application 18
- 4.2 Approval of appliances, accessories, components, equipment, and material 18
- 4.3 Responsibilities of the installer 18
- 4.4 Training and quality of labour 19
- 4.5 Suitability of use 20
- 4.6 Meter and service regulator installations 20
- 4.7 Electrical connections and components 20
- 4.8 Mobile homes 21
- 4.9 Hazardous locations 21
- 4.10 Smoking 21
- 4.11 Isolation of safety devices 21
- 4.12 Leak detection 21
- 4.13 Appliance clearances to combustible material 22
- 4.14 Accessibility 25
- 4.15 Outdoor installations 26
- 4.16 Appliances in garages 26
- 4.17 Appliance ductwork connections 26
- 4.18 Combined heating systems 26
- 4.19 Appliances protected by automatic fire-extinguishing systems 27
- 4.20 Control of appliances with self-energized pilots 27
- 4.21 Defective heat exchangers 27
- 4.22 High-altitude installations 27
- 4.23 Protection of appliances from physical damage 28
- 4.24 Odorization of propane 28

5 Pressure controls 28

- 5.1 Gas system pressure 28
- 5.2 Pressure regulators 29
 - 5.2.1 General 29
 - 5.2.2 Additional requirements for pressure regulators for propane applications 30
 - 5.2.3 Additional requirements for pressure regulators for natural gas applications 30
- 5.3 Relief devices 30
- 5.4 Hydrostatic relief devices for propane applications 31
- 5.5 Venting of pressure control devices 31
- 5.6 Appliance and pilot pressure regulators 33
 - 5.6.1 Appliance and pilot pressure regulators in propane applications 33
 - 5.6.2 Appliance and pilot pressure regulators in natural gas applications 33

6 Piping and tubing systems, hose, and fittings 33

- 6.1 General 33
- 6.2 Material 34
- 6.3 Size 35
- 6.4 Volume of gas to be used for sizing piping and tubing systems 36A
- 6.5 Allowable pressure and pressure drop 37
- 6.6 Extensions 37
- 6.7 Location 37
- 6.8 Piping practices 38
- 6.9 Joints and connections 39
- 6.10 Branch piping outlets 40
- 6.11 Appliance connections 40
- 6.12 Piping outlets 40
- 6.13 Drip and dirt pockets 41
- 6.14 Prohibited practices 41
- 6.15 Underground piping and tubing 42
- 6.16 Protection of piping and tubing 43
- 6.17 Identification of piping or tubing 44A
- 6.18 Manual shut-off valves 45
- 6.19 Manual-reset valves 46
- 6.20 Hose and hose fittings 46
- 6.21 Connectors 47
- 6.22 Testing of piping, tubing, hose, and fittings 48
- 6.23 Purging of piping and tubing systems and hose after leak testing 50
- 6.24 Purging gas from a piping or tubing system 51
- 6.25 Deleted
- 6.26 Rooftop gas piping and tubing 51
- 6.27 Inspection 51

7 Installation of specific types of appliances 52

- 7.1 Boilers 52
- 7.2 Generators, compressors/pressure boosters, stationary engines, and turbines (for natural gas only) 52
 - 7.2.1 General requirements 52
 - 7.2.2 Generators 53
 - 7.2.3 Compressors/pressure boosters 53
 - 7.2.4 Stationary gas engines and turbines 54
 - 7.2.5 Propane-fuelled engines in buildings 54B
- 7.3 Carbon dioxide generators 54C
- 7.4 Commercial-type clothes dryers 54D
- 7.5 Domestic-type clothes dryers 54D
- 7.6 Conversions 54E
- 7.7 Conversion burners 55
- 7.8 Conversion of warm air furnaces 55
- 7.9 Conversion of ranges 56
- 7.10 Counter appliances 56
- 7.11 Direct-vent appliances 56
- 7.12 Furnaces used with cooling units 56
- 7.13 Central furnaces 57
- 7.14 Downflow furnaces 58
- 7.15 Duct furnaces 58
- 7.16 Horizontal furnaces 58
- 7.17 Wall furnaces (recessed heaters) 59
- 7.18 Construction heaters and torches 59

- 7.19 Direct-fired door air heaters 60
- 7.20 Direct-fired make-up air heaters (DFMAH) 60
- 7.21 Non-recirculating direct gas-fired industrial air heaters (DFIAH) 62
- 7.22 Infrared heaters 63
- 7.23 Room heaters 65
- 7.24 Decorative appliances and gas logs 65
- 7.25 Swimming pool heaters 66
- 7.26 Water heaters 67
- 7.27 Unit heaters 68
- 7.28 Hotplates 68
- 7.29 Incinerators 68A
- 7.30 Lighting 69
- 7.31 Commercial cooking appliances 69
- 7.32 Residential-type ranges 70
- 7.33 Refrigerators 70
- 7.34 Stationary gas engines 71
- 7.35 Propane-fuelled engines in buildings 72

8 Venting systems and air supply for appliances 74

- 8.1 General 74
- 8.2 Air supply determination for central-heating furnaces, boilers, and hot-water heaters 74
- 8.3 Air-supply openings and ducts 80
- 8.4 Air-supply requirements for appliances having a total input exceeding 400 000 Btuh (120 kW) 81
- 8.5 Air-supply dampers, louvres, and grilles 81
- 8.6 Conditions created by exhaust fans, air-supply fans, circulating fans, or fireplaces 82
- 8.7 Engineered installations 82
- 8.8 Air supply by mechanical means 82
- 8.9 Appliance venting 82
- 8.10 Methods of venting appliances 83
- 8.11 Vent and chimney requirements 85
- 8.12 Chimneys 85
- 8.13 Vent and chimney sizing 86
- 8.14 Vent and chimney termination 87
- 8.15 Vent and chimney support 90
- 8.16 Vents and chimneys serving two or more appliances 90
- 8.17 Vents outside buildings 90
- 8.18 Vent connectors 91
- 8.19 Chimney connections 94
- 8.20 Size and height of interconnected vent connectors 94
- 8.21 Multi-storey venting 94
- 8.22 Dampers and attachments 95
- 8.23 Draft hoods 95
- 8.24 Venting arrangements 96
- 8.25 Draft regulators 96A
- 8.26 Automatic vent damper or automatic flue damper 97
- 8.27 Manually operated flue dampers 97
- 8.28 Installation of draft-control devices 98
- 8.29 Induced- or forced-draft devices 98
- 8.30 Venting of appliances into canopies 98
- 8.31 Heat reclaimers 99

9 Natural gas compressors and cylinders 99

- 9.1 Installation of compressors 99
- 9.2 Requirements for cylinders 99
- 9.3 Cylinder filling and cylinders 100

- 9.4 Cylinder storage 101
- 9.5 Cylinders connected for use 101

10 Vehicle refuelling appliances (VRA) without storage (for natural gas only) 102

- 10.1 Installation 102
- 10.2 Pressure relief devices and other vents and vent lines 103
- 10.3 Piping, tubing, and hose 103
- 10.4 Testing of piping, hose, and fittings 103
- 10.5 Installation of safety equipment, signs, and/or symbols 104
- 10.6 Refuelling of vehicles 104

Annexes

- A** (informative) — Sizing and capacities of piping and tubing for natural gas 105
- B** (informative) — Sizing and capacities of piping and tubing for propane 141
- C** (informative) — Vent sizing tables for Category I natural gas and propane appliances 168
- D** (informative) — Customer's meter and regulator installations 233
- E** (informative) — Example of piping design sizing (imperial and metric) 235
- F** (informative) — Suggested general dimensions for draft hoods 239
- G** (informative) — Piping expansion and flexibility 242
- H** (normative) — Purging of piping and tubing systems where a readily accessible burner is not available or where an appliance is not equipped with a continuous pilot 244
- I** (informative) — General information 248

Tables

- 4.1** — Appliance clearance reductions with specified forms of protection 23
- 5.1** — Pressure inside buildings 28
- 5.2** — Clearance from discharge, ft (m) 32
- 6.1** — Maximum allowable pressure drop 36
- 6.2** — Spacing of supports for piping 38
- 6.3** — Pressure test requirements 49
- 8.1** — Combustion/dilution air requirements for appliances having draft-control devices when the combined input is up to and including 400 000 Btuh (120 kW) and the structure complies with Clause 8.2.1(a) or (b) 76
- 8.2** — Combustion air requirements for appliances not having draft-control devices when the combined input is up to and including 400 000 Btuh (120 kW) and the structure complies with Clause 8.2.1(a) or (b) 77
- 8.3** — Combustion/dilution air requirements for appliances having draft-control devices when the combined input is up to and including 400 000 Btuh (120 kW) and the structure does not comply with Clause 8.2.1(a) or (b) 78
- 8.4** — Combustion air requirements for appliances not having draft-control devices when the combined input is up to and including 400 000 Btuh (120 kW) and the structure does not comply with Clause 8.2.1(a) or (b) 79
- 8.5** — Type of venting system to be used 84
- 8.6** — Appliance vent connector clearances 92
- 8.7** — Vent connector clearance reductions with specified forms of protection 93

Figures

- 8.1** — Vent passing through a pitched roof 88