

ASME B31.3-2006
(Revision of ASME B31.3-2004)

Process Piping

ASME Code for Pressure Piping, B31

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME B31.3-2006
(Revision of ASME B31.3-2004)

Process Piping

ASME Code for Pressure Piping, B31

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Three Park Avenue • New York, NY 10016

Date of Issuance: May 31, 2007

The next edition of this Code is scheduled for publication in 2008. This Code will become effective 6 months after the Date of Issuance. There will be no addenda issued to this edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. The interpretations will be included with this edition.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 2007 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword	xi
Committee Personnel	xiii
Introduction	xvi
Summary of Changes	xviii
Chapter I Scope and Definitions	1
300 General Statements	1
Chapter II Design	9
Part 1 Conditions and Criteria	9
301 Design Conditions	9
302 Design Criteria	11
Part 2 Pressure Design of Piping Components	17
303 General	17
304 Pressure Design of Components	18
Part 3 Fluid Service Requirements for Piping Components	27
305 Pipe	27
306 Fittings, Bends, Miters, Laps, and Branch Connections	28
307 Valves and Specialty Components	29
308 Flanges, Blanks, Flange Facings, and Gaskets	30
309 Bolting	30
Part 4 Fluid Service Requirements for Piping Joints	31
310 General	31
311 Welded Joints	31
312 Flanged Joints	32
313 Expanded Joints	32
314 Threaded Joints	32
315 Tubing Joints	33
316 Caulked Joints	33
317 Soldered and Brazed Joints	33
318 Special Joints	33
Part 5 Flexibility and Support	33
319 Piping Flexibility	33
321 Piping Support	39
Part 6 Systems	40
322 Specific Piping Systems	40
Chapter III Materials	42
323 General Requirements	42
325 Materials — Miscellaneous	51
Chapter IV Standards for Piping Components	52
326 Dimensions and Ratings of Components	52
Chapter V Fabrication, Assembly, and Erection	55
327 General	55
328 Welding	55
330 Preheating	61
331 Heat Treatment	62
332 Bending and Forming	66
333 Brazing and Soldering	67
335 Assembly and Erection	67

Chapter VI	Inspection, Examination, and Testing	69
340	Inspection	69
341	Examination	69
342	Examination Personnel	75
343	Examination Procedures	75
344	Types of Examination	75
345	Testing	76
346	Records	79
Chapter VII	Nonmetallic Piping and Piping Lined With Nonmetals	80
A300	General Statements	80
Part 1	Conditions and Criteria	80
A301	Design Conditions	80
A302	Design Criteria	80
Part 2	Pressure Design of Piping Components	82
A303	General	82
A304	Pressure Design of Piping Components	82
Part 3	Fluid Service Requirements for Piping Components	83
A305	Pipe	83
A306	Fittings, Bends, Miters, Laps, and Branch Connections	83
A307	Nonmetallic Valves and Specialty Components	84
A308	Flanges, Blanks, Flange Facings, and Gaskets	84
A309	Bolting	84
Part 4	Fluid Service Requirements for Piping Joints	84
A310	General	84
A311	Bonded Joints in Plastics	85
A312	Flanged Joints	85
A313	Expanded Joints	85
A314	Threaded Joints	85
A315	Tubing Joints	85
A316	Caulked Joints	85
A318	Special Joints	85
Part 5	Flexibility and Support	86
A319	Flexibility of Nonmetallic Piping	86
A321	Piping Support	87
Part 6	Systems	88
A322	Specific Piping Systems	88
Part 7	Materials	88
A323	General Requirements	88
A325	Materials — Miscellaneous	89
Part 8	Standards for Piping Components	89
A326	Dimensions and Ratings of Components	89
Part 9	Fabrication, Assembly, and Erection	90
A327	General	90
A328	Bonding of Plastics	90
A329	Fabrication of Piping Lined With Nonmetals	96
A332	Bending and Forming	96
A334	Joining Nonplastic Piping	96
A335	Assembly and Erection	96
Part 10	Inspection, Examination, and Testing	97
A340	Inspection	97
A341	Examination	97
A342	Examination Personnel	98
A343	Examination Procedures	98

A344	Types of Examination	98
A345	Testing	98
A346	Records	99
Chapter VIII	Piping for Category M Fluid Service	100
M300	General Statements	100
Part 1	Conditions and Criteria	100
M301	Design Conditions	100
M302	Design Criteria	100
Part 2	Pressure Design of Metallic Piping Components	101
M303	General	101
M304	Pressure Design of Metallic Components	101
Part 3	Fluid Service Requirements for Metallic Piping Components	101
M305	Pipe	101
M306	Metallic Fittings, Bends, Miters, Laps, and Branch Connections	101
M307	Metallic Valves and Specialty Components	101
M308	Flanges, Blanks, Flange Facings, and Gaskets	102
M309	Bolting	102
Part 4	Fluid Service Requirements for Metallic Piping Joints	102
M310	Metallic Piping, General	102
M311	Welded Joints in Metallic Piping	102
M312	Flanged Joints in Metallic Piping	102
M313	Expanded Joints in Metallic Piping	102
M314	Threaded Joints in Metallic Piping	102
M315	Tubing Joints in Metallic Piping	102
M316	Caulked Joints	102
M317	Soldered and Brazed Joints	102
M318	Special Joints in Metallic Piping	102
Part 5	Flexibility and Support of Metallic Piping	103
M319	Flexibility of Metallic Piping	103
M321	Piping Support	103
Part 6	Systems	103
M322	Specific Piping Systems	103
Part 7	Metallic Materials	103
M323	General Requirements	103
M325	Materials — Miscellaneous	103
Part 8	Standards for Piping Components	103
M326	Dimensions and Ratings of Components	103
Part 9	Fabrication, Assembly, and Erection of Metallic Piping	104
M327	General	104
M328	Welding of Metals	104
M330	Preheating of Metals	104
M331	Heat Treatment of Metals	104
M332	Bending and Forming of Metals	104
M335	Assembly and Erection of Metallic Piping	104
Part 10	Inspection, Examination, Testing, and Records of Metallic Piping	104
M340	Inspection	104
M341	Examination	104
M342	Examination Personnel	105
M343	Examination Procedures	105
M344	Types of Examination	105
M345	Testing	105
M346	Records	105

Parts 11 Through 20, Corresponding to Chapter VII	105
MA300 General Statements	105
Part 11 Conditions and Criteria	105
MA301 Design Conditions	105
MA302 Design Criteria	105
Part 12 Pressure Design of Nonmetallic Piping Components	105
MA303 General	105
MA304 Pressure Design of Nonmetallic Components	105
Part 13 Fluid Service Requirements for Nonmetallic Piping Components	105
MA305 Pipe	105
MA306 Nonmetallic Fittings, Bends, Miters, Laps, and Branch Connections	105
MA307 Nonmetallic Valves and Specialty Components	105
MA308 Flanges, Blanks, Flange Facings, and Gaskets	106
MA309 Bolting	106
Part 14 Fluid Service Requirements for Nonmetallic Piping Joints	106
MA310 General	106
MA311 Bonded Joints	106
MA312 Flanged Joints	106
MA313 Expanded Joints	106
MA314 Threaded Joints	106
MA315 Tubing Joints in Nonmetallic Piping	106
MA316 Caulked Joints	106
MA318 Special Joints	106
Part 15 Flexibility and Support of Nonmetallic Piping	106
MA319 Piping Flexibility	106
MA321 Piping Support	106
Part 16 Nonmetallic and Nonmetallic Lined Systems	106
MA322 Specific Piping Systems	106
Part 17 Nonmetallic Materials	106
MA323 General Requirements	106
Part 18 Standards for Nonmetallic and Nonmetallic Lined Piping Components	106
MA326 Dimensions and Ratings of Components	106
Part 19 Fabrication, Assembly, and Erection of Nonmetallic and Nonmetallic Lined Piping	106
MA327 General	106
MA328 Bonding of Plastics	107
MA329 Fabrication of Piping Lined With Nonmetals	107
MA332 Bending and Forming	107
MA334 Joining Nonplastic Piping	107
MA335 Assembly and Erection	107
Part 20 Inspection, Examination, Testing, and Records of Nonmetallic and Nonmetallic Lined Piping	107
MA340 Inspection	107
MA341 Examination	107
MA342 Examination Personnel	107
MA343 Examination Procedures	107
MA344 Types of Examination	107
MA345 Testing	107
MA346 Records	107
Chapter IX High Pressure Piping	108
K300 General Statements	108
Part 1 Conditions and Criteria	108
K301 Design Conditions	108
K302 Design Criteria	109

Part 2	Pressure Design of Piping Components	111
K303	General	111
K304	Pressure Design of High Pressure Components	111
Part 3	Fluid Service Requirements for Piping Components	114
K305	Pipe	114
K306	Fittings, Bends, and Branch Connections	115
K307	Valves and Specialty Components	115
K308	Flanges, Blanks, Flange Facings, and Gaskets	115
K309	Bolting	116
Part 4	Fluid Service Requirements for Piping Joints	116
K310	General	116
K311	Welded Joints	116
K312	Flanged Joints	116
K313	Expanded Joints	116
K314	Threaded Joints	116
K315	Tubing Joints	116
K316	Caulked Joints	116
K317	Soldered and Brazed Joints	116
K318	Special Joints	117
Part 5	Flexibility and Support	117
K319	Flexibility	117
K321	Piping Support	117
Part 6	Systems	117
K322	Specific Piping Systems	117
Part 7	Materials	118
K323	General Requirements	118
K325	Miscellaneous Materials	121
Part 8	Standards for Piping Components	121
K326	Dimensions and Ratings of Components	121
Part 9	Fabrication, Assembly, and Erection	121
K327	General	121
K328	Welding	121
K330	Preheating	124
K331	Heat Treatment	125
K332	Bending and Forming	126
K333	Brazing and Soldering	126
K335	Assembly and Erection	126
Part 10	Inspection, Examination, and Testing	127
K340	Inspection	127
K341	Examination	127
K342	Examination Personnel	127
K343	Examination Procedures	127
K344	Types of Examination	127
K345	Testing	129
K346	Records	129
Figures		
300.1.1	Diagram Illustrating Application of B31.3 Piping at Equipment	3
302.3.5	Stress Range Factor, f	16
304.2.1	Nomenclature for Pipe Bends	19
304.2.3	Nomenclature for Miter Bends	19
304.3.3	Branch Connection Nomenclature	21
304.3.4	Extruded Outlet Header Nomenclature	23
304.5.3	Blanks	27
319.4.4A	Moments in Bends	37
319.4.4B	Moments in Branch Connections	37

323.2.2A	Minimum Temperatures Without Impact Testing for Carbon Steel Materials	45
323.2.2B	Reduction in Minimum Design Metal Temperature Without Impact Testing	47
328.3.2	Typical Backing Rings and Consumable Inserts	57
328.4.2	Typical Butt Weld End Preparation	57
328.4.3	Trimming and Permitted Misalignment	57
328.4.4	Preparation for Branch Connections	58
328.5.2A	Fillet Weld Size	59
328.5.2B	Typical Details for Double-Welded Slip-On and Socket Welding Flange Attachment Welds	59
328.5.2C	Minimum Welding Dimensions for Socket Welding Components Other Than Flanges	60
328.5.4A	Typical Welded Branch Connections	60
328.5.4B	Typical Welded Branch Connections	60
328.5.4C	Typical Welded Branch Connections	60
328.5.4D	Acceptable Details for Branch Attachment Welds	60
328.5.4E	Acceptable Details for Branch Attachment Suitable for 100% Radiography	61
328.5.5	Typical Fabricated Laps	61
335.3.3	Typical Threaded Joints Using Straight Threads	68
341.3.2	Typical Weld Imperfections	73
A328.5	Typical Plastic Piping Joints	95
K323.3.3	Example of an Acceptable Impact Test Specimen	121
K328.4.3	Pipe Bored for Alignment: Trimming and Permitted Misalignment	124
K328.5.4	Some Acceptable Welded Branch Connections Suitable for 100% Radiography	125
Tables		
300.4	Status of Appendices in B31.3	8
302.3.3C	Increased Casting Quality Factors, E_c	14
302.3.3D	Acceptance Levels for Castings	14
302.3.4	Longitudinal Weld Joint Quality Factor, E_j	15
304.1.1	Values of Coefficient Y for $t < D/6$	18
304.4.1	BPV Code References for Closures	25
308.2.1	Permissible Sizes/Rating Classes for Slip-On Flanges Used as Lapped Flanges	30
314.2.1	Minimum Thickness of Male Threaded Components	32
323.2.2	Requirements for Low Temperature Toughness Tests for Metals	43
323.2.2A	Tabular Values for Minimum Temperatures Without Impact Testing for Carbon Steel Materials	46
323.3.1	Impact Testing Requirements for Metals	48
323.3.4	Charpy Impact Test Temperature Reduction	49
323.3.5	Minimum Required Charpy V-Notch Impact Values	50
326.1	Component Standards	53
330.1.1	Preheat Temperatures	63
331.1.1	Requirements for Heat Treatment	64
341.3.2	Acceptance Criteria for Welds and Examination Methods for Evaluating Weld Imperfections	70
A323.2.2	Requirements for Low Temperature Toughness Tests for Nonmetals	89
A323.4.2C	Recommended Temperature Limits for Reinforced Thermosetting Resin Pipe	89
A323.4.3	Recommended Temperature Limits for Thermoplastics Used as Linings	90
A326.1	Component Standards	91
A341.3.2	Acceptance Criteria for Bonds	98
K302.3.3D	Acceptable Severity Levels for Steel Castings	111

K305.1.2	Required Ultrasonic or Eddy Current Examination of Pipe and Tubing for Longitudinal Defects	115
K323.3.1	Impact Testing Requirements	120
K323.3.5	Minimum Required Charpy V-Notch Impact Values	122
K326.1	Component Standards	123
K341.3.2	Acceptance Criteria for Welds	128
Appendices		
Appendix A	Allowable Stresses and Quality Factors for Metallic Piping and Bolting	
	Materials	131
	Specification Index for Appendix A	132
	Notes for Appendix A Tables	135
	Table A-1 Basic Allowable Stresses in Tension for Metals	139
	Iron	
	Castings	139
	Carbon Steel	
	Pipes and Tubes	140
	Pipes (Structural Grade)	144
	Plates and Sheets	144
	Plates and Sheets (Structural)	146
	Forgings and Fittings	146
	Castings	146
	Low and Intermediate Alloy Steel	
	Pipes	148
	Plates	150
	Forgings and Fittings	152
	Castings	154
	Stainless Steel	
	Pipes and Tubes	156
	Plates and Sheets	160
	Forgings and Fittings	162
	Bar	166
	Castings	166
	Copper and Copper Alloy	
	Pipes and Tubes	168
	Plates and Sheets	168
	Forgings	170
	Castings	170
	Nickel and Nickel Alloy	
	Pipes and Tubes	172
	Plates and Sheets	174
	Forgings and Fittings	176
	Rod and Bar	178
	Castings	178
	Titanium and Titanium Alloy	
	Pipes and Tubes	180
	Plates and Sheets	180
	Forgings	180
	Zirconium and Zirconium Alloy	
	Pipes and Tubes	180
	Plates and Sheets	180
	Forgings and Bar	180
	Aluminum Alloy	
	Seamless Pipes and Tubes	182
	Welded Pipes and Tubes	183
	Structural Tubes	183
	Plates and Sheets	184
	Forgings and Fittings	186
	Castings	187

Table A-1A Basic Casting Quality Factors, E_c	188
Table A-1B Basic Quality Factors for Longitudinal Weld Joints in Pipes, Tubes, and Fittings, E_j	189
Carbon Steel	189
Low and Intermediate Alloy Steel	189
Stainless Steel	190
Copper and Copper Alloy	190
Nickel and Nickel Alloy	191
Titanium and Titanium Alloy	191
Zirconium and Zirconium Alloy	191
Aluminum Alloy	191
Table A-2 Design Stress Values for Bolting Materials	192
Carbon Steel	192
Alloy Steel	192
Stainless Steel	192
Copper and Copper Alloy	198
Nickel and Nickel Alloy	198
Aluminum Alloy	200
Appendix B Stress Tables and Allowable Pressure Tables for Nonmetals	202
Appendix C Physical Properties of Piping Materials	207
Appendix D Flexibility and Stress Intensification Factors	224
Appendix E Reference Standards	228
Appendix F Precautionary Considerations	234
Appendix G Safeguarding	238
Appendix H Sample Calculations for Branch Reinforcement	239
Appendix J Nomenclature	243
Appendix K Allowable Stresses for High Pressure Piping	254
Appendix L Aluminum Alloy Pipe Flanges	268
Appendix M Guide to Classifying Fluid Services	271
Appendix P Alternative Rules for Evaluating Stress Range	273
Appendix Q Quality System Program	275
Appendix S Piping System Stress Analysis Examples	276
Appendix V Allowable Variations in Elevated Temperature Service	289
Appendix X Metallic Bellows Expansion Joints	291
Appendix Z Preparation of Technical Inquiries	296
Index	297

FOREWORD

Responding to evident need and at the request of The American Society of Mechanical Engineers, the American Standards Association initiated Project B31 in March 1926, with ASME as sole administrative sponsor. The breadth of the field involved required that membership of the Sectional Committee be drawn from some 40 engineering societies, industries, government bureaus, institutes, and trade associations.

Initial publication in 1935 was as the American Tentative Standard Code for Pressure Piping. Revisions from 1942 through 1955 were published as American Standard Code for Pressure Piping, ASA B31.1. It was then decided to publish as separate documents the various industry Sections, beginning with ASA B31.8-1955, Gas Transmission and Distribution Piping Systems. The first Petroleum Refinery Piping Code Section was designated ASA B31.3-1959. ASA B31.3 revisions were published in 1962 and 1966.

In 1967–1969, the American Standards Association became first the United States of America Standards Institute, then the American National Standards Institute. The Sectional Committee became American National Standards Committee B31 and the Code was renamed the American National Standard Code for Pressure Piping. The next B31.3 revision was designated ANSI B31.3-1973. Addenda were published through 1975.

A draft Code Section for Chemical Plant Piping, prepared by Section Committee B31.6, was ready for approval in 1974. It was decided, rather than have two closely related Code Sections, to merge the Section Committees and develop a joint Code Section, titled Chemical Plant and Petroleum Refinery Piping. The first edition was published as ANSI B31.3-1976.

In this Code, responsibility for piping design was conceptually integrated with that for the overall processing facility, with safeguarding recognized as an effective safety measure. Three categories of Fluid Service were identified, with a separate Chapter for Category M Fluid Service. Coverage for nonmetallic piping was introduced. New concepts were better defined in five Addenda, the last of which added Appendix M, a graphic aid to selection of the proper Fluid Service category.

The Standards Committee was reorganized in 1978 as a Committee operating under ASME procedures with ANSI accreditation. It is now the ASME Code for Pressure Piping, B31 Committee. Section committee structure remains essentially unchanged.

The second edition of Chemical Plant and Petroleum Refinery Piping was compiled from the 1976 Edition and its five Addenda, with nonmetal requirements editorially relocated to a separate Chapter. Its new designation was ANSI/ASME B31.3-1980.

Section Committee B31.10 had a draft Code for Cryogenic Piping ready for approval in 1981. Again, it was decided to merge the two Section Committees and develop a more inclusive Code with the same title. The work of consolidation was partially completed in the ANSI/ASME B31.3-1984 Edition.

Significant changes were made in Addenda to the 1984 Edition: integration of cryogenic requirements was completed; a new stand-alone Chapter on high-pressure piping was added; and coverage of fabrication, inspection, testing, and allowable stresses was reorganized. The new Edition was redesignated as ASME/ANSI B31.3-1987 Edition.

Addenda to subsequent Editions, published at three-year intervals, have been primarily to keep the Code up-to-date. New Appendices have been added, however, on requirements for bellows expansion joints, estimating service life, submittal of Inquiries, aluminum flanges, and quality control in the 1990, 1993, 1999, and 2002 Editions, all designated as ASME B31.3.

In a program to clarify the application of all Sections of the Code for Pressure Piping, changes are being made in the Introduction and Scope statements of B31.3, and its title is changed to Process Piping.

Under direction of ASME Codes and Standards management, metric units of measurement are being emphasized. With certain exceptions, SI metric units were listed first in the 1996 Edition and were designated as the standard. Instructions for conversion are given where metric data

are not available. U.S. customary units also are given. By agreement, either system may be used.

In this Edition of the Code, SI metric units are given first, with U.S. customary units in parentheses. Appendices H and X, the tables in Appendices A and K, and Tables C-1, C-3, and C-6 in Appendix C are exceptions. Values in metric units are to be regarded as the standard, unless otherwise agreed between the contracting parties. Instructions are given, in those tables that have not been converted for converting tabular data in U.S. units to appropriate SI units.

Interpretations and Code Cases are published on the ASME website. Go to <http://cstools.asme.org>, click on Committee Central, click on Board on Pressure Technology Codes and Standards, click on B31 Code for Pressure Piping Standards Committee, and then click on B31.3 Process Piping Section Committee.

ASME CODE FOR PRESSURE PIPING, B31

(The following is the roster of the Committee at the time of approval of this Code.)

OFFICERS

D. R. Frikken, *Chair*
K. C. Bodenhamer, *Vice Chair*
P. D. Stumpf, *Secretary*

COMMITTEE PERSONNEL

H. A. Ainsworth , Consultant	E. Michalopoulos , Consultant
R. J. T. Appleby , ExxonMobil Upstream Research Co.	M. L. Nayyar , Bechtel Power Corp.
C. Becht IV , Becht Engineering Co.	T. J. O'Grady II , Veco Alaska
A. E. Beyer , Fluor Daniel	R. G. Payne , Alstom Power Inc.
K. C. Bodenhamer , Enterprise Products Co.	J. T. Powers , Parsons Energy & Chemicals
J. S. Chin , El Paso Corp.	E. H. Rinaca , Consultant
D. L. Coym , Worley Parsons	M. J. Rosenfeld , Kiefner & Associates Inc.
D. M. Fox , Atmos Energy	R. J. Silvia , Process Engineers and Constructors Inc.
J. W. Frey , Stress Engineering Services, Inc.	W. J. Sperko , Sperko Engineering Services Inc.
D. R. Frikken , Becht Engineering Co.	G. W. Spohn III , Coleman Spohn Corp.
R. A. Grichuk , Fluor Corp.	P. D. Stumpf , The American Society of Mechanical Engineers
L. E. Hayden, Jr. , Engineering Consultant	A. L. Watkins , The Perry Nuclear Power Plant
G. A. Jolly , Consultant	R. B. West , State of Iowa Division of Labor Services
W. J. Koves , UOP LLC	P. D. Flenner , <i>Ex-Officio Member</i> , Flenner Engineering Services
R. P. Merrill , Evapco Inc.	R. W. Haupt , <i>Ex-Officio Member</i> , Pressure Piping Engineering Associates Inc.
J. E. Meyer , Louis Perry & Associates, Inc.	

B31.3 PROCESS PIPING SECTION COMMITTEE

C. Becht IV , <i>Chair</i> , Becht Engineering Co.	T. W. Johnson , ABB Lummus Global Inc.
J. E. Meyer , <i>Vice Chair</i> , Louis Perry & Associates, Inc.	D. B. Kadakia , TD Williamson, Inc.
N. Lobo , <i>Secretary</i> , The American Society of Mechanical Engineers	W. J. Koves , UOP LLC
B. L. Agee , GE Gas Turbines	J. C. Luf , Washington Group International
R. M. Bojarczuk , ExxonMobil Research & Engineering Co.	W. N. McLean , Newco Valves
D. D. Christian , Victaulic	R. A. McLeod , General Electric Gas Turbines
D. L. Coym , Worley Parsons	R. J. Medvick , Swagelok
J. A. D'Avanzo , DuPont Engineering	V. B. Molina III , Air Products & Chemicals, Inc.
D. W. Diehl , COADE Inc.	C. A. Moore , Smith Fibercast
D. R. Edwards , ConocoPhillips	J. R. Offutt , Chevron
J. P. Ellenberger , Consultant	J. M. Prawdzik , BP
R. W. Engle , The Dow Chemical Co.	D. W. Raho , CCM 2000
W. H. Eskridge, Jr. , Aker Kvaerner E&C	A. P. Rangus , Bechtel
D. J. Fetzner , BP Exploration Alaska Inc.	G. C. Reinhardt II , Team Industries Inc.
D. R. Fraser , NASA Ames Research Center	K. S. Shipley , Consulting Engineer
D. R. Frikken , Becht Engineering Co.	R. J. Silvia , Process Engineers & Constructors Inc.
D. C. Glover , Halliburton Technical Services Co.	J. L. Smith , Jacobs Engineering Group
O. R. Greulich , NASA	F. W. Tatar , FM Global
R. A. Grichuk , Fluor Corp.	Q. N. Truong , Refinery Technology Inc.
B. S. Harris , Consultant	G. E. Woods , Technip USA
R. W. Haupt , Pressure Piping Engineering Associates Inc.	R. J. Young , Consultant
J. F. Hodgins , Car-Ber Testing Services	C. G. Ziu , Orion Fittings, Inc.
R. D. Hookway , Hookway Engineering	J. T. Wier , <i>Honorary Member</i> , Consultant

B31.3 SUBGROUP ON ACTIVITIES

G. A. Babuder, Swagelok Co.
B. C. Bassett, Consultant
R. K. Broyles, Senior Flexonics Pathway
G. Burnett, IPEX Inc.
M. A. Clark, NIBCO Inc.
E. P. Coghlan, LSI Logic
A. D'Angelo, Fix N Tow
R. B. Davis, Ershigs Inc.
P. J. Guerrieri, Sr., Integrated Mechanical Services, Inc.
D. A. McGriff, ISCO Industries, LLC

T. R. McPherson, IPS Corp.
A. D. Nalbandian, Thielsch Engineering Inc.
C. Nath, DuPont Engineering
G. J. Peak, Spears Manufacturing Co.
E. V. Peterson, Boeing
C. D. Pham, SBM Offshore Inc.
R. A. Sierra, Fluor
X. Tang, Swagelok Co.
L. S. Varone, Shaw Stone & Webster
C. T. Widder, Jacobs NTEC

B31.3 INTERNATIONAL REVIEW NETWORK OF EXPERTS

D. Saile, Shell Global Solutions International
R. W. Temple, Engineering Consultant

F. Zezula, BP Exploration Co.

B31 FABRICATION AND EXAMINATION COMMITTEE

P. D. Flenner, *Chair*, Flenner Engineering Services
P. D. Stumpf, *Secretary*, The American Society of Mechanical Engineers
J. P. Ellenberger, Consultant
R. J. Ferguson, Xaloy Inc.
D. J. Fetzner, BP Exploration Alaska Inc.
W. W. Lewis, E. I. DuPont
S. P. Licud, Consultant

A. D. Nalbandian, Thielsch Engineering Inc.
A. P. Rangus, Bechtel
R. I. Seals, Consultant
R. J. Silvia, Process Engineers & Constructors Inc.
W. J. Sperko, Sperko Engineering Services Inc.
E. F. Summers, Jr., Babcock & Wilcox Construction Co.
P. L. Vaughan, Northern Plains Natural Gas Co. LLC

B31 MATERIALS TECHNICAL COMMITTEE

M. L. Nayyar, *Chair*, Bechtel Power Corp.
N. Lobo, *Secretary*, The American Society of Mechanical Engineers
M. H. Barnes, Sebesta Blomberg & Associates
J. A. Cox, Consultant
R. P. Deubler, BGA Engineering
P. J. Dobson, Cummings & Barnard Inc.
W. H. Eskridge, Jr., Aker Kvaerner E&C
R. A. Grichuk, Fluor Corp.

C. L. Henley, Black and Veatch
R. P. Merrill, Evapco Inc.
D. W. Rahoji, CCM 2000
R. A. Schmidt, Hackney Ladish Inc.
H. R. Simpson, PM&C Engineering
J. L. Smith, Jacobs Engineering Group
Z. Djilali, *Corresponding Member*, BEREP

B31 MECHANICAL DESIGN TECHNICAL COMMITTEE

R. W. Haupt, *Chair*, Pressure Piping Engineering Associates Inc.
T. Lazar, *Secretary*, The American Society of Mechanical Engineers
G. A. Antaki, Washington Group
C. Becht IV, Becht Engineering Co.
J. P. Breen, Alion Science and Technology
J. P. Ellenberger, Consultant
D. J. Fetzner, BP Exploration Alaska Inc.
J. A. Graziano, Tennessee Valley Authority
J. D. Hart, SSD, Inc.
B. P. Holbrook, Babcock Power Inc.
W. J. Koves, UOP LLC

G. D. Mayers, Anteon Corp.
T. Q. McCawley, TQM Engineering PC
J. C. Minichiello, Bechtel National Inc. — WTP
T. J. O'Grady II, Veco Alaska
A. W. Paulin, Paulin Resource Group
R. A. Robleto, Senior Technical Advisor
M. J. Rosenfeld, Kiefner & Associates Inc.
G. Stevick, Berkeley Engineering & Research Inc.
E. A. Wais, Wais and Associates Inc.
E. C. Rodabaugh, *Honorary Member*, Consultant

B31 CONFERENCE GROUP

- T. A. Bell**, Bonneville Power Administration
G. Bynog, The National Board of Boiler and Pressure Vessel Inspectors
R. A. Coomes, Commonwealth of Kentucky
D. H. Hanrath, Consultant
C. J. Harvey, Alabama Public Service Commission
D. T. Jagger, Ohio Department of Commerce
M. Kotb, Engineer
K. T. Lau, Alberta Boilers Safety Association
R. G. Marini, New Hampshire Public Utilities Commission
I. W. Mault, Manitoba Department of Labour and Immigration
A. W. Meiring, Fire and Building Boiler and Pressure Vessel Division — Indiana
- R. F. Mullaney**, Boiler and Pressure Vessel Safety Branch — Vancouver
P. Sher, State of Connecticut
M. E. Skarda, Department of Labor
D. A. Starr, Nebraska Department of Labor
D. J. Stursma, Iowa Utilities Board
R. P. Sullivan, The National Board of Boiler and Pressure Vessel Inspectors
J. E. Troppman, Division of Labor/State of Colorado
C. H. Walters, National Board of Boiler and Pressure Vessel Inspectors
W. A. M. West, Lighthouse Assistance Inc.
T. F. Wickham, Rhode Island Department of Labor

INTRODUCTION

The ASME B31 Code for Pressure Piping consists of a number of individually published Sections, each an American National Standard, under the direction of ASME Committee B31, Code for Pressure Piping.

Rules for each Section reflect the kinds of piping installations considered during its development, as follows:

B31.1 Power Piping: piping typically found in electric power generating stations, in industrial and institutional plants, geothermal heating systems, and central and district heating and cooling systems

B31.3 Process Piping: piping typically found in petroleum refineries, chemical, pharmaceutical, textile, paper, semiconductor, and cryogenic plants, and related processing plants and terminals

B31.4 Pipeline Transportation Systems for Liquid Hydrocarbons and Other Liquids: piping transporting products which are predominately liquid between plants and terminals and within terminals, pumping, regulating, and metering stations

B31.5 Refrigeration Piping: piping for refrigerants and secondary coolants

B31.8 Gas Transportation and Distribution Piping Systems: piping transporting products which are predominately gas between sources and terminals, including compressor, regulating, and metering stations; gas gathering pipelines

B31.9 Building Services Piping: piping typically found in industrial, institutional, commercial, and public buildings, and in multi-unit residences, which does not require the range of sizes, pressures, and temperatures covered in B31.1

B31.11 Slurry Transportation Piping Systems: piping transporting aqueous slurries between plants and terminals and within terminals, pumping, and regulating stations

This is the B31.3 Process Piping Code Section. Hereafter, in this Introduction and in the text of this Code Section B31.3, where the word *Code* is used without specific identification, it means this Code Section.

It is the owner's responsibility to select the Code Section which most nearly applies to a proposed piping installation. Factors to be considered by the owner include: limitations of the Code Section; jurisdictional requirements; and the applicability of other codes and standards. All applicable requirements of the selected Code Section shall be met. For some installations, more than one Code Section may apply to different parts of the installation. The owner is also responsible for imposing requirements supplementary to those of the Code if necessary to assure safe piping for the proposed installation.

Certain piping within a facility may be subject to other codes and standards, including but not limited to the following:

ANSI Z223.1 National Fuel Gas Code: piping for fuel gas from the point of delivery to the connection of each fuel utilization device

NFPA Fire Protection Standards: fire protection systems using water, carbon dioxide, halon, foam, dry chemicals, and wet chemicals

NFPA 99 Health Care Facilities: medical and laboratory gas systems

building and plumbing codes, as applicable, for potable hot and cold water, and for sewer and drain systems

The Code sets forth engineering requirements deemed necessary for safe design and construction of pressure piping. While safety is the basic consideration, this factor alone will not necessarily govern the final specifications for any piping installation. The designer is cautioned that the Code is not a design handbook; it does not do away with the need for the designer or for competent engineering judgment.

To the greatest possible extent, Code requirements for design are stated in terms of basic design principles and formulas. These are supplemented, as necessary, with specific requirements to assure uniform application of principles and to guide selection and application of piping elements.

The Code prohibits designs and practices known to be unsafe and contains warnings where caution, but not prohibition, is warranted.

This Code Section includes the following:

- (a) references to acceptable material specifications and component standards, including dimensional requirements and pressure–temperature ratings
- (b) requirements for design of components and assemblies, including piping supports
- (c) requirements and data for evaluation and limitation of stresses, reactions, and movements associated with pressure, temperature changes, and other forces
- (d) guidance and limitations on the selection and application of materials, components, and joining methods
- (e) requirements for the fabrication, assembly, and erection of piping
- (f) requirements for examination, inspection, and testing of piping

ASME Committee B31 is organized and operates under procedures of The American Society of Mechanical Engineers that have been accredited by the American National Standards Institute. The Committee is a continuing one, and keeps all Code Sections current with new developments in materials, construction, and industrial practice. New editions are published at intervals of two years.

Code users will note that clauses in the Code are not necessarily numbered consecutively. Such discontinuities result from following a common outline, insofar as practical, for all Code Sections. In this way, corresponding material is correspondingly numbered in most Code Sections, thus facilitating reference by those who have occasion to use more than one Section.

It is intended that this edition of Code Section B31.3 not be retroactive. Unless agreement is specifically made between contracting parties to use another issue, or the regulatory body having jurisdiction imposes the use of another issue, the latest edition issued at least 6 months prior to the original contract date for the first phase of activity covering a piping installation shall be the governing document for all design, materials, fabrication, erection, examination, and testing for the piping until the completion of the work and initial operation.

Users of this Code are cautioned against making use of Code revisions without assurance that they are acceptable to the proper authorities in the jurisdiction where the piping is to be installed.

The B31 Committee has established an orderly procedure to consider requests for interpretation and revision of Code requirements. To receive consideration, such request must be in writing and must give full particulars in accordance with Appendix Z.

The approved reply to an inquiry will be sent directly to the inquirer. In addition, the question and reply will be published as part of an Interpretation supplement.

A Case is the prescribed form of reply when study indicates that the Code wording needs clarification, or when the reply modifies existing requirements of the Code or grants permission to use new materials or alternative constructions. The Case will be published as part of a Case supplement.

A Case is normally issued for a limited period. If at the end of that period it has been incorporated in the Code, or if no further use of its provisions is anticipated, it will be allowed to expire. Otherwise, it will be renewed for a limited period.

A request for revision of the Code will be placed on the Committee's agenda. Further information or active participation on the part of the proponent may be requested during consideration of a proposed revision.

Materials ordinarily are listed in the stress tables only when sufficient usage in piping within the scope of the Code has been shown. Requests for listing shall include evidence of satisfactory usage and specific data to permit establishment of allowable stresses, maximum and minimum temperature limits, and other restrictions. Additional criteria can be found in the guidelines for addition of new materials in the ASME Boiler and Pressure Vessel Code, Section II and Section VIII, Division 1, Appendix B. (To develop usage and gain experience, unlisted materials may be used in accordance with para. 323.1.2.) Metric versions of Tables A-1 and A-2 are in the course of preparation. Please refer to the B31.3 Process Piping Web pages at <http://cstools.asme.org/csconnect/CommitteePages.cfm>.

SUMMARY OF CHANGES

Following approval by the B31 Committee and ASME, and after public review, ASME B31.3-2006 was approved by the American National Standards Institute on November 14, 2006.

Changes given below are identified on the pages by a margin note, **(06)**, placed next to the affected area.

<i>Page</i>	<i>Location</i>	<i>Change</i>
14	302.3.5(c)	Second sentence corrected by errata
16	Fig. 302.3.5	Title corrected by errata
17	302.3.5(e)	Revised
18	304.1.2(a)	In eq. (3a), <i>W</i> added by errata
20, 22	304.3.3(a)	In nomenclature for <i>t</i> , two parentheses in penultimate sentence deleted by errata
26, 27	304.5.1	Revised in its entirety
	304.5.2	Nomenclature for S_f corrected by errata
	304.5.3	(1) Subparagraph (a) added and existing text designated as (b) (2) In eq. (15), <i>W</i> added by errata
	304.7.2	Title and first paragraph revised
30	307.2	Subparagraph 307.2.2 added and existing text designated as para. 307.2.1
	Table 308.2.1	Column for PN deleted
31	309.2.1	Revised
	309.2.2	Revised
35, 36	319.3.6	Revised
52	326.1.2	Revised
54	Table 326.1	Under Miscellaneous, title of MSS SP-73 revised
55	328.2.2(e)	Revised
64	Table 331.1.1	In fourth column, first, second, third, fourth, third-to-last, and second-to-last entries revised
70	Table 341.3.2	Under Examination Methods, Visual, sixth entry corrected by errata
76	344.6.1	Cross-references in first paragraph and subparagraph (a) revised
78	345.4.2(c)	Revised
81	A302.3	Title revised
	A302.3.2	In footnote 1, titles of ASTM D 2321 and D 2837 revised

<i>Page</i>	<i>Location</i>	<i>Change</i>
82	A304.1.2	Title revised
83	A304.5	Title revised
	A304.5.1	Revised in its entirety
	A305	Revised
	A306	Title revised
84	A308.2.1	Revised
	A309.3	Revised
88	A323.2	Title revised
91, 92	Table A326.1	(1) Under Nonmetallic Fittings, titles revised for ASTM D 2467, D 3309, D 4024, and F 439 (2) Under Nonmetallic Fittings, ASTM F 423, F 491, F 492, F 546, F 599, and F 781 deleted (3) Under Nonmetallic Pipes and Tubes, titles revised for ASTM D 2672, D 3035, D 3309, F 441, and F 1673 (4) Under Nonmetallic Pipes and Tubes, ASTM F 423, F 491, F 492, F 546, F 599, and F 781 deleted (5) Under Miscellaneous, titles revised for ASTM D 2564 and D 2672
93	A328.2.5(b)	Footnote 5 revised
94	A328.5.5	Reference to footnote 5 added
97	A335.4.1	Revised
101	M306.4.2(b)	Revised
106	MA323.4.2	Revised
108	K300(a)	Revised
111, 112	K304.1.2	Revised in its entirety
118	K323.1.1	Revised in its entirety
119	K323.3.4(a)	Revised
122	K328.2.5	Deleted
123	Table K326.1	ASME B1.20.1 added
124	K328.4.3(a)(1)	In fourth line, measurement corrected by errata to read 1.5 mm
127	K341.4.1(b)(1)	Revised
135, 137	Notes for Appendix A Tables	In Note (75), metric tabular values added by errata
144	Table A-1	Under Carbon Steel, Pipes and Tubes, for API 5L Grades X65, X70, and X80, Note (77) added by errata

<i>Page</i>	<i>Location</i>	<i>Change</i>
152, 153	Table A-1	Under Low and Intermediate Alloy Steel, Forgings and Fittings, for $1\frac{1}{4}\text{Cr}-\frac{1}{2}\text{Mo}$ A 234, Grade corrected by errata to read WP11
166	Table A-1	Under Stainless Steel, Castings, for A 351 Grade CD3M-W-Cu-N, S-No. corrected by errata to read S-10H
176, 177	Table A-1	Under Nickel and Nickel Alloy, Plates and Sheets, third B 688 N08367 deleted by errata
182	Table A-1	Under Aluminum Alloy, Seamless Pipes and Tubes, B 241 Grade 5652 deleted
193	Table A-2	Under Carbon Steel, for A 194, Grade 2 transferred from first line to second line by errata
203	Specification Index for Appendix B	Titles revised for ASTM D 2672, D 3035, and D 3309
205	Table B-1	For PEEK material, maximum recommended Celsius temperature corrected by errata to read 230
228–233	Appendix E	<ol style="list-style-type: none"> (1) First paragraph revised (2) ASTM A 508/A 508M, A 723/A 723M, B 338, B 363, D 1527, D 1600, D 1785 through D 2282, D 2321 through D 2467, D 2513 through D 2657, D 2672 through D 2855, D 3035 through D 3839, D 4024, E213, F 336, F 438, F 439, F 441/F 441M, F 493, and F 1055 through F 1673 updated (3) ASTM B 861, D 6041, F 714, and F 1970 added (4) ASTM F 423, F 491, F 492, F 546, F 599, and F 781 deleted (5) AISC M016 added (6) For ASME publications, years deleted (7) MSS SP-53 and SP-73 updated (8) PFI ES-7 updated (9) Addresses for AISC, CGA, PPI, and ANSI updated
243–253	Appendix J	<ol style="list-style-type: none"> (1) For c, D, E, I_i, P, S, S_A, S_E, S_{hr}, S_L, \bar{T}, t, $t_{m'}$ and Y, para. S300 added by errata (2) For E_{ar}, para. P319.4.4 added by errata (3) Entries for F_{ar}, f, and f_m corrected by errata (4) For second N_E and N_i entries, reference transferred into Paragraph column by errata

<i>Page</i>	<i>Location</i>	<i>Change</i>
		(5) Entries for P_i , S_{cr} , and T_j corrected by errata (6) Definition for S_{om} corrected by errata (7) Revised
254	Appendix K	(1) ASTM B 337 deleted (2) ASTM B 861 added
266, 267	Table K-1	Under Titanium and Titanium Alloy, all lines revised
268	L300	Revised
269	Table L301.2M	Column heads revised
	L303.2.3	Revised
	L303.3.2	Revised
272	Fig. M300	In Col. 3, fourth box, cross-reference corrected by errata to read para. 300(d)(4)
273	P302.3.5	(1) First paragraph corrected by errata (2) Nomenclatures for eqs. (P1a) and (P1d) deleted by errata
276	S300.1	Revised
280–288	S302	Added
	S303	Added
292	X302.1.2(c)	Corrected by errata
293	Fig. X302.1.3	General Note (a) revised
295	X302.2.2(b)	In third line, measurement corrected by errata to read 2.4 mm
	X302.2.3	Revised in its entirety

NOTES:

- (1) The interpretations to ASME B31.3 issued between November 1, 2003 and October 31, 2005 follow the last page of this edition as a separate supplement, Interpretations Volume 20.
- (2) After the interpretations, a separate supplement containing Case 178 follows.

Page intentionally blank

Chapter I

Scope and Definitions

300 GENERAL STATEMENTS

(a) *Identification.* This Process Piping Code is a Section of the American Society of Mechanical Engineers Code for Pressure Piping, ASME B31, an American National Standard. It is published as a separate document for convenience of Code users.

(b) *Responsibilities*

(1) *Owner.* The owner of a piping installation shall have overall responsibility for compliance with this Code, and for establishing the requirements for design, construction, examination, inspection, and testing which will govern the entire fluid handling or process installation of which the piping is a part. The owner is also responsible for designating piping in certain fluid services and for determining if a specific Quality System is to be employed. [See paras. 300(d)(4), (d)(5), (e), and Appendix Q.]

(2) *Designer.* The designer is responsible to the owner for assurance that the engineering design of piping complies with the requirements of this Code and with any additional requirements established by the owner.

(3) *Manufacturer, Fabricator, and Erector.* The manufacturer, fabricator, and erector of piping are responsible for providing materials, components, and workmanship in compliance with the requirements of this Code and of the engineering design.

(4) *Owner's Inspector.* The owner's Inspector (see para. 340) is responsible to the owner for ensuring that the requirements of this Code for inspection, examination, and testing are met. If a Quality System is specified by the owner to be employed, the owner's inspector is responsible for verifying that it is implemented.

(c) *Intent of the Code*

(1) It is the intent of this Code to set forth engineering requirements deemed necessary for safe design and construction of piping installations.

(2) This Code is not intended to apply to the operation, examination, inspection, testing, maintenance, or repair of piping that has been placed in service. The provisions of this Code may optionally be applied for those purposes, although other considerations may also be necessary.

(3) Engineering requirements of this Code, while considered necessary and adequate for safe design, generally employ a simplified approach to the subject. A designer capable of applying a more rigorous analysis

shall have the latitude to do so; however, the approach must be documented in the engineering design and its validity accepted by the owner. The approach used shall provide details of design, construction, examination, inspection, and testing for the design conditions of para. 301, with calculations consistent with the design criteria of this Code.

(4) Piping elements should, insofar as practicable, conform to the specifications and standards listed in this Code. Piping elements neither specifically approved nor specifically prohibited by this Code may be used provided they are qualified for use as set forth in applicable Chapters of this Code.

(5) The engineering design shall specify any unusual requirements for a particular service. Where service requirements necessitate measures beyond those required by this Code, such measures shall be specified by the engineering design. Where so specified, the Code requires that they be accomplished.

(6) Compatibility of materials with the service and hazards from instability of contained fluids are not within the scope of this Code. See para. F323.

(d) *Determining Code Requirements*

(1) Code requirements for design and construction include fluid service requirements, which affect selection and application of materials, components, and joints. Fluid service requirements include prohibitions, limitations, and conditions, such as temperature limits or a requirement for safeguarding (see para. 300.2 and Appendix G). Code requirements for a piping system are the most restrictive of those which apply to any of its elements.

(2) For metallic piping not in Category M or high pressure fluid service, Code requirements are found in Chapters I through VI (the base Code), and fluid service requirements are found in

- (a) Chapter III for materials
- (b) Chapter II, Part 3, for components
- (c) Chapter II, Part 4, for joints

(3) For nonmetallic piping and piping lined with nonmetals, all requirements are found in Chapter VII. (Paragraph designations begin with "A.")

(4) For piping in a fluid service designated by the owner as Category M (see para. 300.2 and Appendix M), all requirements are found in Chapter VIII. (Paragraph designations begin with "M.")

(5) For piping in a fluid service designated by the owner as Category D (see para. 300.2 and Appendix M),

piping elements restricted to Category D Fluid Service in Chapters I through VII, as well as elements suitable for other fluid services, may be used.

(6) Metallic piping elements suitable for Normal Fluid Service in Chapters I through VI may also be used under severe cyclic conditions unless a specific requirement for severe cyclic conditions is stated.

(e) *High Pressure Piping.* Chapter IX provides alternative rules for design and construction of piping designated by the owner as being in High Pressure Fluid Service.

(1) These rules apply only when specified by the owner, and only as a whole, not in part.

(2) Chapter IX rules do not provide for Category M Fluid Service. See para. K300.1.4.

(3) Paragraph designations begin with "K."

(f) *Appendices.* Appendices of this Code contain Code requirements, supplementary guidance, or other information. See para. 300.4 for a description of the status of each Appendix.

300.1 Scope

Rules for the Process Piping Code Section B31.3¹ have been developed considering piping typically found in petroleum refineries; chemical, pharmaceutical, textile, paper, semiconductor, and cryogenic plants; and related processing plants and terminals.

300.1.1 Content and Coverage

(a) This Code prescribes requirements for materials and components, design, fabrication, assembly, erection, examination, inspection, and testing of piping.

(b) This Code applies to piping for all fluids, including

- (1) raw, intermediate, and finished chemicals
- (2) petroleum products
- (3) gas, steam, air, and water
- (4) fluidized solids
- (5) refrigerants
- (6) cryogenic fluids

(c) See Fig. 300.1.1 for a diagram illustrating the application of B31.3 piping at equipment. The joint connecting piping to equipment is within the scope of B31.3.

300.1.2 Packaged Equipment Piping. Also included within the scope of this Code is piping which interconnects pieces or stages within a packaged equipment assembly.

300.1.3 Exclusions. This Code excludes the following:

(a) piping systems designed for internal gage pressures at or above zero but less than 105 kPa (15 psi), provided the fluid handled is nonflammable, nontoxic, and not damaging to human tissues as defined in 300.2,

¹B31 references here and elsewhere in this Code are to the ASME B31 Code for Pressure Piping and its various Sections, which are identified and briefly described in the Introduction.

and its design temperature is from -29°C (-20°F) through 186°C (366°F)

(b) power boilers in accordance with BPV Code² Section I and boiler external piping which is required to conform to B31.1

(c) tubes, tube headers, crossovers, and manifolds of fired heaters, which are internal to the heater enclosure

(d) pressure vessels, heat exchangers, pumps, compressors, and other fluid handling or processing equipment, including internal piping and connections for external piping

300.2 Definitions

Some of the terms relating to piping are defined below. For welding, brazing, and soldering terms not shown here, definitions in accordance with AWS Standard A3.0³ apply.

air-hardened steel: a steel that hardens during cooling in air from a temperature above its transformation range.

anneal heat treatment: see *heat treatment*.

arc cutting: a group of cutting processes wherein the severing or removing of metals is effected by melting with the heat of an arc between an electrode and the base metal. (Includes carbon-arc cutting, metal-arc cutting, gas metal-arc cutting, gas tungsten-arc cutting, plasma-arc cutting, and air carbon-arc cutting.) See also *oxygen-arc cutting*.

arc welding (AW): a group of welding processes which produces coalescence of metals by heating them with an arc or arcs, with or without the application of pressure and with or without the use of filler metal.

assembly: the joining together of two or more piping components by bolting, welding, bonding, screwing, brazing, soldering, cementing, or use of packing devices as specified by the engineering design.

automatic welding: welding with equipment which performs the welding operation without adjustment of the controls by an operator. The equipment may or may not perform the loading and unloading of the work.

backing filler metal: see *consumable insert*.

backing ring: material in the form of a ring used to support molten weld metal.

balanced piping system: see para. 319.2.2(a).

²BPV Code references here and elsewhere in this Code are to the ASME Boiler and Pressure Vessel Code and its various Sections as follows:

- Section I, Power Boilers
- Section II, Materials, Part D
- Section V, Nondestructive Examination
- Section VIII, Pressure Vessels, Divisions 1 and 2
- Section IX, Welding and Brazing Qualifications

³AWS A3.0, Standard Welding Terms and Definitions, Including Terms for Adhesive Bonding, Brazing, Soldering, Thermal Coupling and Thermal Spraying